



# Sub Divisional Level Water Testing Laboratory



## UTTARAKHAND JAL SANSTHAN HALDWANI, NAINITAL

### Water Quality Test Report


Name of the Customer/ Organization:	EMMANUEL PUBLIC SCHOOL ,Near Roopnagar gate,Mukhani Haldwani.	Sample Description	EMMANUEL PUBLIC SCHOOL ,Near Roopnagar gate,Mukhani Haldwani.
Type of Water (Surface water/Ground water)	Drinking -Water	Start of analysis	07.06.2023
Sample Code:	EPS-59	Sample collected By	Customer
Sample Receiving Date and Time:	07.06.2023 10.35Am	Date of Issue Report	08.06.2023


### Testing Details


S.N.	Parameters	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Results
1	Colour (Hazen units)	5	15	Less Than 05
2	Odour (Agreeable)	Agreeable	Agreeable	Agreeable
3	pH@25*c	6.5 to 8.5	No relaxation	8.20
4	Alkalinity as CaCo3 (mg/l)	200	600	164
5	Turbidity (NTU)	1	5	0.36
6	Total dissolved solid (mg/l)	500	2000	192
7	Chloride (mg/l)	250	1000	4.9
8	Total hardness (mg/l)	200	600	156
9	Calcium(as ca) (mg/l)	75	200	49.6
10	Magnesium (mg/l)	30	100	7.7
11	Total coliform (MPN/100ML)*	Absent	Absent	ABSENT
12	E.Coli (MPN/100ML)*	Absent	Absent	ABSENT


\*Indicates-Parameters that are not NABL-accredited.

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

  
CHEMIST, 58/06/2023  
SDLWDTML,  
UJS Haldwani (Nainital)

  
Manager  
Emmanuel Public School  
Roopnagar Mukhani  
Haldwani (Nainital)

  
Principal  
Emmanuel Public School  
Roopnagar Mukhani  
Haldwani (Nainital)

  
Technical Manager in-charge of lab  
TECHNICAL MANAGER  
Sub-Divisional (Nainital)  
Water Quality Testing  
& Monitoring Laboratory  
UJS Haldwani (Nainital)

\*\*END OF REPORT\*\*